Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

CERTIFICATIONS

Project: NYSD - BLDG 16-1st FLOOR
Pace Project No.: 10366445

Minnesota Certification IDs
1700 Elm Street SE Suite 200, Minneapolis, MN 55414
Alaska Certification UST-107
525 N 8th Street, Salina, KS 67401
A2LA Certification #: 2926.01
Alaska Certification #: UST-078
Alaska Certification #MN00064
Alabama Certification #40770
Arizona Certification #: AZ-0014
Arkansas Certification #: 88-0680
California Certification #: 01155CA
Colorado Certification #Pace
Connecticut Certification #: PH-0256
EPA Region 8 Certification #: 8TMS-L
Florida/NELAP Certification #: E87605
Guam Certification #:14-008r
Georgia Certification #: 959
Georgia EPD #: Pace
Idaho Certification #: MN00064
Hawaii Certification #MN00064
Illinois Certification #: 200011
Indiana Certification#C-MN-01
Iowa Certification #: 368

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

SAMPLE SUMMARY

Project: NYSD - BLDG 16-1st FLOOR
Pace Project No.: 10366445

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10366445001	Room 014/ Sink	Water	10/08/16 03:04	10/14/16 09:45
10366445002	Room 016/ Sink	Water	10/08/16 03:03	10/14/16 09:45
10366445003	Room 017/Left Sink	Water	10/08/16 03:05	10/14/16 09:45
10366445004	Room 017/Right Sink	Water	10/08/16 03:06	10/14/16 09:45
10366445005	Room 014/Fountain	Water	10/08/16 03:07	10/14/16 09:45
10366445006	Room 004/Sink	Water	10/08/16 03:08	10/14/16 09:45
10366445007	Room 206/Sink	Water	10/08/16 03:11	10/14/16 09:45
10366445008	Room 209/Fountain	Water	10/08/16 03:12	10/14/16 09:45
10366445009	Room 212/Right Sink	Water	10/08/16 03:14	10/14/16 09:45
10366445010	Room 212/Left Sink	Water	10/08/16 03:14	10/14/16 09:45
10366445011	Room 213/Left Sink	Water	10/08/16 03:15	10/14/16 09:45
10366445012	Room 213/Right Sink	Water	10/08/16 03:16	10/14/16 09:45
10366445013	Room 300/ Sink	Water	10/08/16 03:19	10/14/16 09:45
10366445014	Room 304/ Sink	Water	10/08/16 03:19	10/14/16 09:45
10366445015	Room 315/ Sink	Water	10/08/16 03:22	10/14/16 09:45
10366445016	Room 316/ Sink	Water	10/08/16 03:21	10/14/16 09:45
10366445017	Room 317/ Sink	Water	10/08/16 03:21	10/14/16 09:45
10366445018	Room 347/Hallwa4107.6 (1 l2(a0 0 0 1 Tf 29.062 0 Td [(W)37 (ater)-4070.1 (10/08/16 03:21)-2050 (10/14/16 09:45)]TJ ET Q q 1 0 0 1 2			

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

SAMPLE SUMMARY

Project: NYSD - BLDG 16-1st FLOOR
Pace Project No.: 10366445

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10366445038	Room 100/Sink	Water	10/08/16 03:48	10/14/16 09:45
10366445039	Room 103/Sink	Water	10/08/16 03:50	10/14/16 09:45
10366445040	Room 127/Sink	Water	10/08/16 03:51	10/14/16 09:45
10366445041	Room 133/Sink	Water	10/08/16 03:53	10/14/16 09:45
10366445042	Room 131/Sink	Water	10/08/16 03:53	10/14/16 09:45
10366445043	Room 132/Sink	Water	10/08/16 03:52	10/14/16 09:45
10366445044	Room 122/Sink	Water	10/08/16 03:57	10/14/16 09:45
10366445045	Room 123/Sink	Water	10/08/16 03:56	10/14/16 09:45
10366445046	Room 124/Sink	Water	10/08/16 03:56	10/14/16 09:45
10366445047	Room 125/Sink	Water	10/08/16 03:54	10/14/16 09:45
10366445048	Room 149/Sink	Water	10/08/16 03:55	10/14/16 09:45
10366445049	Room 142/KitJ ET Q qS[(103B 2e)37]P1Scjr/t47s 100 Tz 0 Tr 8 0 W ouL0.1Pantry/16 03:55			10/14/16 09:45

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

SAMPLE ANALYTE COUNT

Project:

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

SAMPLE ANALYTE COUNT

Project: NYSD - BLDG 16-1st FLOOR
Pace Project No.: 10366445

Lab ID	Sample ID	Method	Analysts	Analytes	

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

ANALYTICAL RESULTS

Project: NYSD - BLDG 16-1st FLOOR
Pace Project No.: 10366445

Sample: Room 014/ Sink Lab ID: 10366445001 Collected: 10/08/16 03:04 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	37.5	ug/L	0.10	1		10/21/16 12:01	7439-92-1	

Sample: Room 016/ Sink Lab ID: 10366445002 Collected: 10/08/16 03:03 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	19.9	ug/L	0.10	1		10/21/16 12:08	7439-92-1	

Sample: Room 017/Left Sink Lab ID: 10366445003 Collected: 10/08/16 03:05 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	37.8	ug/L	0.10	1		10/21/16 12:09	7439-92-1	

Sample: Room 017/Right Sink Lab ID: 10366445004 Collected: 10/08/16 03:06 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	165	ug/L	0.10	1		10/21/16 12:10	7439-92-1	

Sample: Room 014/Fountain Lab ID: 10366445005 Collected: 10/08/16 03:07 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	2210	ug/L	2.0	20		10/22/16 11:26	7439-92-1	

Sample: Room 004/Sink Lab ID: 10366445006 Collected: 10/08/16 03:08 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	33.2	ug/L	0.10	1		10/21/16 12:13	7439-92-1	

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

ANALYTICAL RESULTS

Project: NYSD - BLDG 16-1st FLOOR
Pace Project No.: 10366445

Sample: Room 300/ Sink Lab ID: 10366445013 Collected: 10/08/16 03:19 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW								
Lead								

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

ANALYTICAL RESULTS

Project: NYSD - BLDG 16-1st FLOOR
Pace Project No.: 10366445

Sample: Room 312/Sink Lab ID: 10366445019 Collected: 10/08/16 03:25 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	28.8	ug/L	0.10	1		10/21/16 12:37	7439-92-1	

Sample: Room 309/Sink Lab ID: 10366445020 Collected: 10/08/16 03:26 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	6.3	ug/L	0.10	1		10/21/16 12:38	7439-92-1	

Sample: Room 331/Sink Lab ID: 10366445021 Collected: 10/08/16 03:31 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	1.3	ug/L	0.10	1		10/24/16 17:54	7439-92-1	

Sample: Room 330/Sink Lab ID: 10366445022

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

ANALYTICAL RESULTS

Project: NYSD - BLDG 16-1st FLOOR
Pace Project No.: 10366445

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

ANALYTICAL RESULTS

Project: NYSD - BLDG 16-1st FLOOR
Pace Project No.: 10366445

Sample: Room 110/Sink Lab ID: 10366445031 Collected: 10/08/16 03:41 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.46	ug/L	0.10	1		10/24/16 18:12	7439-92-1	

Sample: Room 112/Sink Lab ID: 10366445032 Collected: 10/08/16 03:42 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	14.5	ug/L	0.10	1		10/24/16 18:15	7439-92-1	

Sample: Room 115/Sink Lab ID: 10366445033 Collected: 10/08/16 03:47 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.74	ug/L	0.10	1		10/24/16 18:16	7439-92-1	

Sample: Room 116/Sink Lab ID: 10366445034 Collected: 10/08/16 03:45 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.33	ug/L	0.10	1		10/24/16 18:17	7439-92-1	

Sample: Room 117/Sink Lab ID: 10366445035 Collected: 10/08/16 03:45 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.28	ug/L	0.10	1		10/24/16 18:18	7439-92-1	

Sample: Room 118/Sink Lab ID: 10366445036 Collected: 10/08/16 03:44 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.36	ug/L	0.10	1		10/24/16 18:22	7439-92-1	

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

ANALYTICAL RESULTS

Project: NYSD - BLDG 16-1st FLOOR
Pace Project No.: 10366445

Sample: Room 148/Sink Lab ID: 10366445037 Collected: 10/08/16 03:46 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.30	ug/L	0.10	1		10/24/16 18:23	7439-92-1	

Sample: Room 100/Sink Lab ID: 10366445038 Collected: 10/08/16 03:48 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.33	ug/L	0.10	1		10/24/16 18:25	7439-92-1	

Sample: Room 103/Sink Lab ID: 10366445039 Collected: 10/08/16 03:50 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.62	ug/L	0.10	1		10/24/16 18:26	7439-92-1	

Sample: Room 127/Sink Lab ID: 10366445040 Collected: 10/08/16 03:51 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.47	ug/L	0.10	1		10/24/16 18:27	7439-92-1	

Sample: Room 133/Sink Lab ID: 10366445041 Collected: 10/08/16 03:53 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.48	ug/L	0.10	1		10/21/16 19:05	7439-92-1	

Sample: Room 131/Sink Lab ID: 10366445042 Collected: 10/08/16 03:53 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	10.5	ug/L	0.10	1		10/21/16 19:12	7439-92-1	

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

ANALYTICAL RESULTS

Project: NYSD - BLDG 16-1st FLOOR
Pace Project No.: 10366445

Sample: Room 132/Sink Lab ID: 10366445043 Collected: 10/08/16 03:52 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	1.0	ug/L	0.10	1		10/21/16 19:13	7439-92-1	

Sample: Room 122/Sink Lab ID: 10366445044 Collected: 10/08/16 03:57 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.70	ug/L	0.10	1		10/21/16 19:15	7439-92-1	

Sample: Room 123/Sink Lab ID: 10366445045 Collected: 10/08/16 03:56 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.34	ug/L	0.10	1		10/21/16 19:16	7439-92-1	

Sample: Room 124/Sink Lab ID: 10366445046 Collected: 10/08/16 03:56 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.28	ug/L	0.10	1		10/21/16 19:17	7439-92-1	

Sample: Room 125/Sink Lab ID: 10366445047 Collected: 10/08/16 03:54 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS	Analytical Method: EPA 200.8 Preparation Method: EPA 200.8							
Lead	1.0	ug/L	0.10	1	10/22/16 12:49	10/25/16 01:06	7439-92-1	

Sample: Room 149/Sink Lab ID: 10366445048 Collected: 10/08/16 03:55 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.19	ug/L	0.10	1		10/21/16 19:18	7439-92-1	

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

ANALYTICAL RESULTS

Project: NYSD - BLDG 16-1st FLOOR
Pace Project No.: 10366445

Sample: Room 142/Kitchen Sink Lab ID: 10366445049 Collected: 10/08/16 03:59 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	3.6	ug/L	0.10	1		10/21/16 19:19	7439-92-1	

Sample: Room 142/Pantry Sink Lab ID: 10366445050 Collected: 10/08/16 04:00 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	102	ug/L	0.10	1		10/21/16 19:23	7439-92-1	

Sample: Room 139/ Sink Lab ID: 10366445051 Collected: 10/08/16 04:02 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	0.95	ug/L	0.10	1		10/21/16 19:24	7439-92-1	

Sample: Room 144/ Sink Lab ID: 10366445052 Collected: 10/08/16 04:00 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	103	ug/L	0.10	1		10/21/16 19:26	7439-92-1	

Sample: Room 314/Slop Lab ID: 10366445053 Collected: 10/08/16 04:50 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	5.2	ug/L	0.10	1		10/22/16 17:40	7439-92-1	

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

QUALITY CONTROL DATA

Project: NYSD - BLDG 16-1st FLOOR
Pace Project No.: 10366445

QC Batch: 441878 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
Associated Lab Samples: 10366445001, 10366445002, 10366445003, 10366445004, 10366445005, 10366445006, 10366445007, 10366445008, 10366445009, 10366445010, 10366445011, 10366445012, 10366445013, 10366445014, 10366445015, 10366445016, 10366445017, 10366445018, 10366445019, 10366445020

METHOD BLANK: 2406359 Matrix: Water
Associated Lab Samples: 10366445001, 10366445002, 10366445003, 10366445004, 10366445005, 10366445006, 10366445007, 10366445008, 10366445009, 10366445010, 10366445011, 10366445012, 10366445013, 10366445014, 10366445015, 10366445016, 10366445017, 10366445018, 10366445019, 10366445020

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/21/16 11:51	

LABORATORY CONTROL SAMPLE: 2406360

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	104	104	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2410577 2410578

Parameter	Units	10366445001 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	37.5	100	100	142	137	104	100	70-130	3	20	

MATRIX SPIKE SAMPLE: 2410579

Parameter	Units	10366445011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	7.4	100	118	110	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

QUALITY CONTROL DATA

Project: NYSD - BLDG 16-1st FLOOR
Pace Project No.: 10366445

QC Batch: 441879 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
Associated Lab Samples: 10366445021, 10366445022, 10366445023, 10366445024, 10366445025, 10366445026, 10366445027, 10366445028, 10366445029, 10366445030, 10366445031, 10366445032, 10366445033, 10366445034, 10366445035, 10366445036, 10366445037, 10366445038, 10366445039, 10366445040

METHOD BLANK: 2406362 Matrix: Water
Associated Lab Samples: 10366445021, 10366445022, 10366445023, 10366445024, 10366445025, 10366445026, 10366445027, 10366445028, 10366445029, 10366445030, 10366445031, 10366445032, 10366445033, 10366445034, 10366445035, 10366445036, 10366445037, 10366445038, 10366445039, 10366445040

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/24/16 17:49	

LABORATORY CONTROL SAMPLE: 2406363

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	103	103	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2414119 2414120

Parameter	Units	10366445021 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	1.3	100	100	106	98.5	105	97	70-130	7	20	

MATRIX SPIKE SAMPLE: 2414121

Parameter	Units	10366445031 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	0.46	100	98.6	98	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

QUALITY CONTROL DATA

Project: NYSD - BLDG 16-1st FLOOR
Pace Project No.: 10366445

QC Batch: 442569 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
Associated Lab Samples: 10366445041, 10366445042, 10366445043, 10366445044, 10366445045, 10366445046, 10366445048, 10366445049, 10366445050, 10366445051, 10366445052

METHOD BLANK: 2411674 Matrix: Water
Associated Lab Samples: 10366445041, 10366445042, 10366445043, 10366445044, 10366445045, 10366445046, 10366445048, 10366445049, 10366445050, 10366445051, 10366445052

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/21/16 18:55	

LABORATORY CONTROL SAMPLE: 2411675

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	112	112		

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

QUALITY CONTROL DATA

Project: NYSD - BLDG 16-1st FLOOR
Pace Project No.: 10366445

QC Batch: 442629
QC Batch Method: EPA 200.8
Analysis Method: EPA 200.8
Analysis Description: 200.8 MET
Associated Lab Samples: 10366445047

METHOD BLANK: 2412541 Matrix: Water
Associated Lab Samples: 10366445047

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	0.10	0.10	10/25/16 01:00	P8

LABORATORY CONTROL SAMPLE: 2412542

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	102	102	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2412543 2412544

Parameter	Units	10366445047 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	1.0	100	100	105	105	104	104	70-130	0	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

QUALIFIERS

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

QUALITY CONTROL DATA CROSS19fFFERENCE A

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: NYSD - BLDG 16-1st FLOOR
Pace Project No.: 10366445

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10366445050	Room 142/Pantry Sink	EPA 200.8	442569		
10366445051	Room 139/ Sink	EPA 200.8	442569		
10366445052	Room 144/ Sink	EPA 200.8	442569		
10366445053	Room 314/Slop	EPA 200.8	441882		
10366445047	Room 125/Sink	EPA 200.8	442629	EPA 200.8	442888

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Sample Condition **Client Name:** **Project #:**

10/19/16